

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7300-1657:213 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** GE Security, Inc., 8985 Town Center Parkway, Bradenton, FL 34202  
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

**DESIGN:** Model "Fireworks" FW2, FW4, FW2UL2, FW4UL2, FW3UL3, and FW5UL3 System Control Computer. Consists of the main PC with several required peripherals. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

FW2, FW4, FW2UL2, FW4UL2, FW3UL3, FW5UL3	System Control Computer
PCWD, PCWDSW (factory installed)	Computer Card
FW-PP	Parallel port expander card
FW-SND	Sound card
FW-HD	Second hard drive
FW-MOD	Modem card
FW-SP	Serial port expander card
FW-ZIP	Internal zip drive
FW-VIDVC	PCI Video Card
FW-VIDVC2	AGP Video Card
FW-VIDTVC	PCI TV Video Card for CCTV
APS or BPS	Power Supply
PCCA	Computer Mounting Hardware
Mini-Mux, FCOM-FIB, and MEGA Buffer	Printed Circuit Boards
FW-19MN, -19MNTS, -19MON, -19MONTs,	Monitors
FW-21MN, -21MNTS, -21MON, P260	Monitors
FW-18LCD, FW18LCDTS, FW-19LCDTS	LCD Monitors
FW-RACKLCD	Rack Mount Kit for FW-18LCD and/or FW-18LCDTS Monitors
FW-SP2, FW-SP4	Serial Cards

**RATING:** 120/240 VAC 50/60Hz

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as system control computer for use with listee's separately listed Models EST-3 (CSFM Listing No. 7165-1657:186 & 7170-1657:187), EST-2 (CSFM Listing No. 7170-1657:195), IRC-3 (CSFM Listing No. 7165-1657:147 & 7170-1657:157) and FCC (CSFM Listing No. 7165-1657:139 & 7170-1657:158) fire alarm control units. Refer to listee's Installation Instruction Manual for details.

**NOTE:** Formerly 7300-1591:213 and 7300-1388:247



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 9, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*

